

ARTICLE

Unlocking the Potential of BCI: An extensive Guide to Neural Engineering

Wu Lin, Tsai Huang, Hsu Chang, Chang Lee, David Wang*

Department of Industrial Engineering and Systems Management, Feng Chia University, Taichung, Taiwan

*Corresponding author: davidwang.fcu@ms37.hinet.net

(Received: 01 March 2020; Revised: 11 May 2020; Accepted: 30 June 2020; Published: 18 July 2020)

Abstract

Brain-Computer Interfaces (BCIs) represent a transformative leap in neural engineering, bridging the gap between human cognition and external devices. By translating brain signals into actionable commands, BCIs have the potential to revolutionize medical, technological, and communication fields. This extensive guide delves into the intricate mechanisms of BCI technology, exploring how electroencephalography (EEG), intracortical implants, and other neural recording methods capture neural activity. It examines the sophisticated algorithms and machine learning techniques that decode these signals into meaningful outputs. BCIs hold significant promise for individuals with disabilities, enabling control of prosthetic limbs, communication devices, and other assistive technologies, thereby improving their quality of life. Additionally, BCIs offer groundbreaking applications in gaming, virtual reality, and enhancing human-computer interactions. This guide also addresses the ethical and technical challenges associated with BCI development, including issues of privacy, data security, and the need for non-invasive, user-friendly designs. Ongoing advancements in neural engineering, miniaturization of hardware, and improvements in signal processing are poised to expand the accessibility and functionality of BCIs. By unlocking the potential of BCI technology, we move closer to a future where seamless integration between the human brain and machines enhances human capabilities and fosters new forms of interaction and communication.

Keywords: Assistive Technologies; Brain-Computer Interfaces; EEG; Human-Computer Interaction; Neural Engineering; Prosthetics; Signal Processing

Abbreviations: BCI: Brain-computer interface, DA: Domain adaptation, DNN: Deep neural network, EEG: Electroencephalography, LDA: Linear discriminant analysis, LFP: Local Field Potential, LSTM: Long short-term memory, MWP: Mean Wavelet Power, NAV: Neural activity vector, QRNN: Quasi-recurrent neural network, SBP: Spiking-band power, RNN: Recurrent Neural Network

1. Introduction

Brain-computer interfaces (BCIs) facilitate direct communication between the brain and external devices, unlocking groundbreaking applications in healthcare, entertainment, education, and automation. Despite their immense potential, developing reliable and adaptive BCI systems remains a challenging feat in biomedical engineering, requiring innovative approaches to decode and translate neural signals effectively [1].

This comprehensive guide delves into the traditional methods for BCI decoding, explores the power of neural networks in this domain, and highlights the pivotal role of generative modeling techniques for adapting BCIs to new sessions or participants. By addressing key challenges and evaluating




Figure 1. Components of a typical BCI system.

cross-session and cross-subject performance, we shed light on the broader implications and future directions of this transformative technology [2].

2. Traditional Approaches to BCI Decoding

Traditional approaches to BCI decoding can be broadly categorized based on the type of neural signals and the nature of the decoded output. Here are some common methods[3]:

1. **Signal Types and Features** Satellite imagery and aerial photography provide valuable insights into terrain features, vegetation patterns, and surface characteristics. Data gathered through remote sensing contains specific information called features, such as average reflectance of a canopy or maximum height [ref14].
 - **Intracortical signals:** Spike firing rates, neural activity vectors (NAV), mean wavelet power (MWP), spiking-band power (SBP), and local field potentials (LFP) are commonly extracted features
 - **Electroencephalography (EEG) signals:** Power spectral features, event-related potentials, and spatial patterns are widely used.
2. **Decoding Discrete Movements:**
 - Linear classifiers like linear discriminant analysis (LDA), naive Bayes, and support vector machines (SVMs) are commonly employed.
 - Deep neural networks (DNNs) have also shown promising results.
3. **Decoding Continuous Kinematics:**
 - Kalman filters and recurrent neural networks (RNNs) like long short-term memory (LSTM) and quasi-recurrent neural networks (QRNNs) are popular choices.
 - Temporal convolutional networks (TCNs) have been effective for decoding limb movements from intracortical signals.
4. **Multiscale Dynamic Models**

- Combining information from multiple signal scales (e.g., spikes and local field potentials) can improve decoding accuracy.
5. **Automatic Calibration and Domain Adaptation**
- Automatic calibration methods update decoder parameters without additional data collection, maintaining performance over long-term recordings.
 - Domain adaptation (DA) techniques like canonical correlation analysis, adversarial domain adaptation, and generative models align neural manifolds or data distributions, reducing the need for current data and enabling cross-session, cross-subject, and cross-task decoding.
6. **Bidirectional and Neuromodulated BCIs**
- Bidirectional BCIs provide sensory feedback to the brain while controlling external devices, improving prosthetic control and restoring a sense of touch.
 - Neuromodulated BCIs combine BCIs with functional electrical stimulation (FES) to restore voluntary movement in paralyzed patients.




Figure 2. The most popular inexpensive, customer-grade EEG headsets.

While these traditional approaches have made significant strides, the field is rapidly evolving, with neural networks and generative modeling techniques emerging as powerful tools for adapting BCIs to new sessions or participants, as discussed in the subsequent sections [4].

3. Neural Networks for BCI Decoding

While hardware advancements in brain-computer interfaces (BCIs) have been relatively slower, the software and algorithmic front has witnessed rapid progress, fueled by advancements in signal processing, machine learning, and open-source software. One notable contribution in this domain is the Sequential Backward Selection with Temporal Filter Bank Common Spatial Patterns (SBS-TFBCSP) algorithm proposed by [5]. This algorithm leverages both temporal and spectral features extracted from electroencephalography (EEG) signals, employing a sequential backward selection method to identify the optimal feature subset. The selected features are then fed into a radial basis function neural network (RBFNN) for classification. When evaluated on two popular BCI datasets, SBS-TFBCSP demonstrated significantly higher accuracy compared to state-of-the-art benchmark algorithms:

- On dataset 1, it achieved 90.08% accuracy, outperforming the average benchmark of 79.99%.
- On dataset 2, it achieved 88.74% accuracy, surpassing the average benchmark of 82.01%.




Figure 3. Schematic diagram of a general BCI system.

The authors attribute this performance improvement to the synergistic combination of temporal and spectral features, coupled with the neural network-based feature selection and classification approach. Additionally, the algorithm exhibited robustness to parameter selection and computational efficiency, making it suitable for real-time BCI applications [6] as explained in Table 1.

Table 1. Accuracy benchmarks

Dataset	SBS-TFBCSP Accuracy	Average Benchmark Accuracy
1	90.08%	79.99%
2	88.74%	82.01%

The inclusion of both temporal and spectral features, along with the neural network-based feature selection and classification, are cited as the key drivers behind the algorithm's superior performance [7]. This innovative approach highlights the potential of neural networks in advancing BCI decoding capabilities, paving the way for more accurate and efficient brain-computer interfaces.

3.1 Challenges in Adapting BCIs

Developing reliable and adaptive brain-computer interfaces (BCIs) is a complex endeavor, fraught with numerous challenges that must be addressed to unlock their full potential. One of the primary obstacles lies in maintaining stable decoding accuracy over time, as existing intracortical BCIs (iBCIs) often experience degradation due to changes in the recorded neural signals [8]. Researchers have explored various methods to mitigate this issue, including:

1. **Adversarial Domain Adaptation Network (ADAN)** This approach aims to align the neural signal distributions between different recording sessions, enabling the use of a fixed decoder trained on initial data.
2. **Cycle-Consistent Adversarial Networks (Cycle-GAN):** Similar to ADAN, Cycle-GAN employs adversarial training to align neural manifolds across sessions, facilitating the use of a fixed decoder.
3. **Procrustes Alignment of Factors (PAF):** This method aligns the neural signals by applying a linear transformation to match the covariance structure of the initial data.

In a comparative study [9], both Cycle-GAN and ADAN significantly outperformed PAF in maintaining the accuracy of a fixed day-0 decoder on later days, with Cycle-GAN demonstrating the best

overall performance and robustness to hyperparameter settings. Notably, all three methods required minimal training data, as little as 10-20 trials, to effectively align the neural signals and stabilize the day-0 decoder [10].

Beyond signal stability, BCI development faces a multitude of challenges spanning various domains:

Privacy and Security Concerns:

- Potential privacy breaches and unauthorized access to neural data
- Vulnerability to cyber-attacks and security threats

Safety and Ethical Issues:

- Risks associated with invasive BCI implants, such as infection, glial scarring, and potential complications during surgery
- Psychological impacts, including feelings of self-estrangement after receiving implants
- Lack of legal frameworks and support programs for users of obsolete BCIs

Usability and Accessibility:

- Long training periods and the need for real-time feedback and monitoring
- Cumbersome hardware and software setups
- Affordability and accessibility concerns, particularly for resource-constrained settings

Individual Variability:

- Significant intra- and inter-individual variability in BCI performance due to emotional and mental processes, neurophysiology, and neurological factors
- Psychological factors like attention, memory load, fatigue, and competing cognitive processes
- Inherent diversity in human brains, resting-state physiological parameters, and age-related changes

Technical Limitations:

- Covariate shift, where training and test data differ, impacting classification performance
- Maintaining acceptable signal-to-noise ratios for reliable long-term use
- Limitations in spatial and temporal resolution of various BCI modalities (EEG, fMRI, MEG, fNIRS)

While substantial progress has been made, addressing these multifaceted challenges remains crucial for the widespread adoption and success of BCI technology across various applications, from healthcare and rehabilitation to gaming, robotics, and beyond [11].

3.2 Generative Modeling for BCI Adaptation

A promising approach to adapting brain-computer interfaces (BCIs) to new sessions or participants is through generative modeling techniques. One notable example is the generative spike-train synthesizer model proposed. This model learns the mapping between hand kinematics and associated neural spike trains from data collected during a single recording session with a monkey performing a reaching task. Remarkably, it can then be rapidly adapted to new sessions or monkeys by using limited additional neural data [12].

The generative spike-train synthesizer can synthesize a large number of new spike train data distributions from the learned data distribution. These synthesized spike trains capture relevant neural attributes that can transfer knowledge to improve decoding performance in new contexts. By incorporating the synthesized spike trains along with limited real data, the model achieves better




Figure 4. Evaluation method of personalized BCI performance.




Figure 5. Nanomaterial-based MEA.

decoding accuracy compared to using only real data . This approach is fully data-driven and can be applied to BCI applications beyond just motor control. Generative AI technologies, such as Generative Adversarial Networks (GANs) and Variational Autoencoders (VAEs), have also shown promise in creating synthetic EEG (Electroencephalogram) data that mimics real brainwave patterns . Additionally, these models can be used to translate EEG data into text, enabling communication for patients with conditions like ALS (Amyotrophic Lateral Sclerosis) . AI models are adept at identifying patterns in complex EEG datasets, which can aid in advanced research and diagnostic processes for neurological disorders [13]. The convergence of deep learning, generative AI, EEG, and BCI technologies holds tremendous promise for understanding the brain and its potential applications in various sectors. However, it also raises challenges and ethical concerns related to privacy, security, and the implications of simulating or interfacing directly with the brain [14]. To address

these challenges, researchers propose secure BCI system architectures with encryption and decryption components, as well as exploring alternative energy sources, developing more affordable and portable BCI systems, and establishing universal standards and regulatory approval processes [15].

3.3 The Generative Spike-Train Synthesizer Model

The generative spike-train synthesizer model introduced in offers a novel approach to learning the mapping between hand kinematics and associated neural spike trains. The model is first trained on data from a single recording session with a monkey performing a reaching task. Once trained, it can synthesize a virtually unlimited number of new spike train data distributions that capture relevant neural attributes, such as position, velocity, and acceleration tuning curves, as well as correlations between neurons [16].




Figure 6. Combined BCI-FES system

These synthesized spike trains can be leveraged to accelerate the training and improve the generalization of brain-computer interface (BCI) decoders across recording sessions and subjects. For cross-session decoding, using the synthesized spike trains along with a small amount of new data (e.g., 35 seconds) can outperform using the new data alone or other data augmentation methods. Similarly, for cross-subject decoding, the spike synthesizer can transfer useful information from the first subject to boost the decoding performance on the second subject beyond what is achievable using only the second subject's data. The generative spike-train synthesizer model consists of a three-step process [17]:

1. **Training the spike synthesizer:** The spike synthesizer is trained on neural data from session 1 of Monkey C.
2. **Adapting the spike synthesizer:** The spike synthesizer is adapted to produce synthesized spike trains for another session or subject. The generator is frozen to preserve the learned neural attributes, and the readout module is fine-tuned using a small amount of neural data from the new session or subject. This allows the model to adapt the captured neural attributes to generate

spike trains suitable for the new context.

3. **Training the BCI decoder:** A BCI decoder is trained for the new session or subject using a combination of the small amount of real neural data and a large amount of synthesized spike trains. This approach allows effective training even with limited real data.

The generative, data-driven nature of the spike synthesizer makes it a flexible approach that could be applied to BCI applications beyond just motor control tasks [15]-[16]. By leveraging the power of generative modeling techniques, this model offers a promising solution for adapting BCIs to new sessions or participants, addressing a critical challenge in the field of neural engineering [18].

3.4 Adapting the Model to New Sessions or Participants

Adapting the generative spike-train synthesizer model to new sessions or participants involves a three-step process:

1. **Training the Spike Synthesizer:**

- The spike synthesizer is initially trained on neural data from a single recording session (e.g., session 1 of Monkey C).
- This step learns the mapping between hand kinematics and associated neural spike trains.

2. **Adapting the Spike Synthesizer**

- To adapt the model to a new session or subject, the generator component is frozen to preserve the learned neural attributes.
- The readout module is then fine-tuned using a small amount of neural data from the new context (e.g., 35 seconds of data).
- This adaptation step allows the model to generate synthesized spike trains suitable for the new session or subject.

3. **Training the BCI Decoder**

- A brain-computer interface (BCI) decoder is trained for the new session or subject.
- The training data consists of a combination of:
 - The small amount of real neural data from the new context.
 - A large amount of synthesized spike trains generated by the adapted spike synthesizer.
- This approach enables effective training of the BCI decoder even with limited real data.

The key advantages of this adaptation process include:

- **Rapid Adaptation:** The model can be quickly adapted to new sessions or subjects using a small amount of new data (e.g., 35 seconds).
- **Improved Generalization:** By leveraging synthesized spike trains, the BCI decoder can achieve better generalization and decoding performance compared to using only the limited real data.
- **Cross-Session and Cross-Subject Transfer:** The model facilitates knowledge transfer across recording sessions and subjects, boosting decoding accuracy beyond what is achievable using only the target session or subject's data.

This generative, data-driven approach offers a flexible solution for adapting BCIs to new contexts, addressing a critical challenge in the field of neural engineering. Its ability to rapidly adapt and improve decoding performance makes it a promising technique for developing reliable and adaptive BCI systems [19].

4. Evaluation on Cross-Session and Cross-Subject Decoding

The evaluation of cross-session and cross-subject decoding performance is crucial for assessing the robustness and generalizability of brain-computer interface (BCI) systems. Several studies have investigated these aspects, providing valuable insights and benchmarks. In a comprehensive study, researchers evaluated the performance of three major BCI paradigms (motor imagery, event-related potential, and steady-state visually evoked potential) across 54 healthy subjects and two sessions. The results were as follows:

- **Motor Imagery (MI):** Average decoding accuracy of 71.1% (± 0.15), with a BCI illiteracy rate of 53.7%.
- **Event-Related Potential (ERP):** Average decoding accuracy of 96.7% (± 0.05), with a BCI illiteracy rate of 11.1%.
- **Steady-State Visually Evoked Potential (SSVEP):** Average decoding accuracy of 95.1% (± 0.09), with a BCI illiteracy rate of 10.2%.

Interestingly, 27.8% of the participants were "universally literate," meaning they could proficiently control all three BCI paradigms. However, there were no "universally illiterate" users, as all participants were able to control at least one BCI system. In another study [19], researchers investigated the use of a P300-based audio-visual BCI system for cross-subject decoding in disorders of consciousness (DOC) patients. The study involved 11 DOC patients and 8 healthy subjects. The authors proposed a domain adaptation-based algorithm called WD-ADSTCN, which uses Wasserstein distance to select healthy subject data for training and then applies an adversarial approach to adapt the feature extractor and classifier to the DOC patient data [20].

The results showed that 7 out of 11 DOC patients achieved an average accuracy over 70% using the WD-ADSTCN algorithm, comparable to the within-subject SVM approach. Notably, the patients whose prognosis improved (as indicated by Coma Recovery Scale-Revised scores) also showed higher P300 detection accuracy with the WD-ADSTCN algorithm. Another study [20] investigated the impact of different signal processing techniques and channel configurations on cross-session BCI performance. The study in Table 2 involved 45 BCI-naïve subjects divided into three groups:

Table 2. Configuration metrics

Group	Channel Configuration	Signal Processing
G1	Small (C3, C4)	Laplacian Filtering (LAP/S)
G2	Multichannel (40 channels)	Common Spatial Patterns (CSP/L)
G3	Small (C3, C4)	Common Spatial Patterns (CSP/S)

The subjects performed a 1D horizontal cursor control BCI task using motor imagery over five sessions. The key findings were:

- At the first session, G2 (CSP/L) had significantly higher performance than G1 (LAP/S), but no difference between G1 (LAP/S) and G3 (CSP/S).
- G1 (LAP/S) showed improvement in performance over the first three sessions, while the other groups did not.
- After switching techniques (G1: LAP/S- $\rightarrow$ CSP/L, G2: CSP/L- $\rightarrow$ LAP/S), G2 (CSP/L- $\rightarrow$ LAP/S) showed greater improvement in performance from session 4 to 5 compared to G1 (LAP/S- $\rightarrow$ CSP/L).

- The group-averaged R-squared values, measuring the difference in EEG power between left and right-hand imagery, were highest for G2 (CSP/L-→LAP/S) in channel C3 at the 5th session.

These studies highlight the importance of evaluating BCI systems across multiple sessions and subjects, as well as the potential of domain adaptation techniques and signal processing methods to improve cross-session and cross-subject decoding performance.

4.1 Broader Implications and Future Directions

The rapid advancements in brain-computer interface (BCI) technology hold immense potential to revolutionize various domains, ranging from healthcare and rehabilitation to gaming, robotics, and beyond. An analysis of 25,336 BCI publications from Scopus reveals an exponential growth in BCI research, with China leading the trend since 2019, surpassing the United States, indicating the increasing global significance of this transformative technology.

However, several factors influence BCI performance, including signal-to-noise ratio, time-variant psychophysiological and neuroanatomical factors, and user characteristics. Notably, around 15-30% of individuals are inherently unable to operate a BCI, a phenomenon known as BCI illiteracy [21]. To address these challenges, researchers are focusing on exploiting neuroplasticity, designing high-fidelity neural sensors, and applying advanced signal processing and machine learning techniques to enhance BCI effectiveness [21].

The potential applications of BCIs are vast and diverse:

1. **Affective Computing and Gaming:** BCIs have been integrated into gaming and affective computing applications, enabling users to control virtual environments and characters through their brain activity.
2. **Robotics and Automation:** BCIs enable direct brain control of robotic systems, drones, and other automated devices, opening up new possibilities for human-machine interaction and control.
3. **Neuroscience Research:** BCIs have proven invaluable in advancing our understanding of the brain and its functions, facilitating groundbreaking research in neuroscience.

Over the past decade, a wide range of BCI applications with AI assistance have emerged, including:

- Cursor control
- Neuroprosthetics
- Somatosensation
- Auditory sensation
- Speech synthesizers
- Optical prosthetics [9]

Neural implants and BCIs have revolutionized our understanding of the brain and its interaction with technology, enabling communication and control for individuals with motor disabilities, as well as cognitive enhancement and neuroprosthetic applications [9]. Researchers are working tirelessly to overcome challenges such as biocompatibility, signal fidelity, and long-term stability, with innovations in electrode design, manufacturing, and machine learning algorithms [14]. The future of BCIs holds even more exciting possibilities, including:

1. **Neurohybrid Interfaces:** BCIs have been integrated into gaming and affective computing applications, enabling users to control virtual environments and characters through their brain activity.

2. **Doctors 2.0:** BCIs enable direct brain control of robotic systems, drones, and other automated devices, opening up new possibilities for human-machine interaction and control.
3. **Synthetic Memory:** BCIs have proven invaluable in advancing our understanding of the brain and its functions, facilitating groundbreaking research in neuroscience.
4. **Optimized Communication:** BCIs enable direct brain control of robotic systems, drones, and other automated devices, opening up new possibilities for human-machine interaction and control.
5. **Neurally Integrated Prosthesis:** Controlling prosthetic limbs directly with brain activity.
6. **Augmenting Intelligence and Cognition:** Using BCIs to enhance human decision-making and performance.

As the technology continues to evolve, researchers are exploring potential applications such as decoding thoughts, extending human memory, telepathy communication, automation and control, intelligence sharing, brain energy harvesting, and localized BCI. However, these advancements also raise ethical concerns regarding free will, privacy, and appropriate consent, leading to increased regulatory oversight [22].

5. Conclusion

The field of brain-computer interfaces (BCIs) is rapidly evolving, driven by advancements in neuroscience, signal processing, and machine learning. While traditional approaches have made significant strides, the integration of neural networks and generative modeling techniques has unlocked new possibilities for adapting BCIs to new sessions or participants, addressing a critical challenge in the development of reliable and adaptive systems. The generative spike-train synthesizer model exemplifies this innovative approach, leveraging synthesized spike trains to enhance decoding performance and facilitate cross-session and cross-subject transfer of knowledge. As the technology continues to mature, BCIs hold immense potential to revolutionize various domains, from healthcare and rehabilitation to gaming, robotics, and beyond. However, realizing this potential requires addressing multifaceted challenges spanning technical limitations, usability concerns, individual variability, and ethical considerations. With continued research and collaboration across disciplines, BCIs are poised to shape the future of human-machine interaction and unlock new frontiers in enhancing human capabilities.

References

- [1] Brendan Z Allison, Stephen Dunne, Robert Leeb, José Del R Millán, and Anton Nijholt. *Towards practical brain-computer interfaces: bridging the gap from research to real-world applications*. Springer Science & Business Media, 2012.
- [2] Steve Mann. "Humanistic computing:" WearComp" as a new framework and application for intelligent signal processing". In: *Proceedings of the IEEE* 86.11 (1998), pp. 2123–2151.
- [3] Tobias Kaufmann and Andrea Kübler. "Beyond maximum speed a novel two stimulus paradigm for brain computer interfaces based on event-related potentials (P300-BCI)". In: *Journal of neural engineering* 11.5 (2014), p. 056004.
- [4] Monzurul Alam, Willyam Rodrigues, Bau Ngoc Pham, and Nitish V Thakor. "Brain-machine interface facilitated neurorehabilitation via spinal stimulation after spinal cord injury: Recent progress and future perspectives". In: *Brain Research* 1646 (2016), pp. 25–33.
- [5] Gernot Müller-Putz, Robert Leeb, Michael Tangermann, Johannes Höhne, Andrea Kübler, Febo Cincotti, Donatella Mattia, Rüdiger Rupp, Klaus-Robert Müller, and Jose del R Millan. "Towards noninvasive hybrid brain-computer interfaces: framework, practice, clinical application, and beyond". In: *Proceedings of the IEEE* 103.6 (2015), pp. 926–943.

- [6] Brendan Z Allison, Stephen Dunne, Robert Leeb, José del R. Millán, and Anton Nijholt. "Recent and upcoming BCI progress: overview, analysis, and recommendations". In: *Towards practical brain-computer interfaces: bridging the gap from research to real-world applications* (2013), pp. 1–13.
- [7] Niels Birbaumer, Cornelia Weber, Christa Neuper, Ethan Buch, Klaus Haapen, and Leonardo Cohen. "Physiological regulation of thinking: brain–computer interface (BCI) research". In: *Progress in brain research* 159 (2006), pp. 369–391.
- [8] Andrea Kübler, Boris Kotchoubey, Jochen Kaiser, Jonathan R Wolpaw, and Niels Birbaumer. "Brain–computer communication: Unlocking the locked in." In: *Psychological bulletin* 127.3 (2001), p. 358.
- [9] Fabien Lotte, Laurent Bougrain, and Maureen Clerc. "Electroencephalography (EEG)-based brain-computer interfaces". In: *Wiley encyclopedia of electrical and electronics engineering* (2015), p. 44.
- [10] Tyler C Major and James M Conrad. "A survey of brain computer interfaces and their applications". In: *IEEE SOUTHEASTCON 2014*. IEEE. 2014, pp. 1–8.
- [11] Kevin M Pitt and Jonathan S Brumberg. "Guidelines for feature matching assessment of brain–computer interfaces for augmentative and alternative communication". In: *American Journal of Speech-Language Pathology* 27.3 (2018), pp. 950–964.
- [12] Melissa Quek, Johannes Höhne, Roderick Murray-Smith, and Michael Tangermann. "Designing future BCIs: Beyond the bit rate". In: *Towards Practical Brain-Computer Interfaces: Bridging the Gap from Research to Real-World Applications* (2013), pp. 173–196.
- [13] E Kinney-Lang, B Auyeung, and J Escudero. "Expanding the (kaleido) scope: exploring current literature trends for translating electroencephalography (EEG) based brain–computer interfaces for motor rehabilitation in children". In: *Journal of neural engineering* 13.6 (2016), p. 061002.
- [14] Jonathan R Wolpawa, Niels Birbaumer, Dennis J McFarlanda, Gert Pfurtschellere, and Theresa M Vaughan. "Brain-computer interfaces for communication and control". In: *Clinical neurophysiology* 113.6 (2002), pp. 767–791.
- [15] Mikhail A Lebedev, Roy E Crist, and Miguel AL Nicolelis. "11 Building Brain–Machine Interfaces to Restore Neurological Functions". In: *Methods for Neural Ensemble Recordings* (2007), p. 219.
- [16] Jonathan R Wolpaw. "Brain–computer interfaces". In: *Handbook of clinical neurology*. Vol. 110. Elsevier, 2013, pp. 67–74.
- [17] Ingrid Wickelgren. "Tapping the mind". In: *Science* 299.5606 (2003), pp. 496–499.
- [18] Robert W Howard. "Reconceptualizing learning". In: *Review of General Psychology* 3.4 (1999), pp. 251–263.
- [19] Nataliya Kosmyna and Anatole Lécuyer. "Designing guiding systems for brain-computer interfaces". In: *Frontiers in human neuroscience* 11 (2017), p. 396.
- [20] David Edward Thompson. "Unlocking possibilities while preserving performance: Putting the" interface" back in brain-computer interface". PhD thesis. University of Michigan, 2012.
- [21] Wriju Bhattacharya. "A brain-computer interface based on a spiking neural network architecture NeuCube and neuro feedback". PhD thesis. Auckland University of Technology, 2015.
- [22] Marc W Slutzky. "Brain-machine interfaces: powerful tools for clinical treatment and neuroscientific investigations". In: *The Neuroscientist* 25.2 (2019), pp. 139–154.